




NOTES :

- 1) A MINIMUM OF 150mm (6") BEDDING SAND SHALL BE INSTALLED AROUND CONDUIT CONFORMING TO SSS SECTION 19-3.0025B AND CSS SECTION 86.0.2.02.
- 2) WARNING TAPE SHALL BE TERRA TAPE OR APPROVED EQUAL AND HAVE A WIDTH EQUAL TO OR LARGER THAN THAT OF THE CONDUIT.
- 3) NO OPEN-CUT TRENCH SHALL BE PERMITTED ON EXPRESSWAY LANES UNLESS SPECIFIED OTHERWISE ON PROJECT PLANS.

METRIC (& ENGLISH) UNITS

		SANTA CLARA COUNTY ROADS AND AIRPORTS DEPARTMENT	SUBMITTED: 	APPROVAL: 	STANDARD DETAILS ELECTRICAL CONDUIT TRENCHING REQUIREMENTS	DRAWING NO. E	
NO.	REVISIONS	BY	DATE	APP'D	PROJECT NO.	CONTRACT NO.	FILE NO.

SHEET NO.
45
1 OF 1